

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-0610:113 Page 1 of 1

CATEGORY: Door Closer/Holders/Releasing Devices

LISTED: Dorma Door Controls, PO Box AC, Reamstown PA 17567-0411
Contact: Rick Loose (717) 336-3881 Fax (717) 336-2106

DESIGN: Series TS93 GSR EMF 1I/TS93 GSR EMF 1A, TS93 GSR EMF 2 surface mounted, self-closing type swing door closer. These devices used together to form an electrically actuated coordinated pair of doors closer.

Series TS93 U1/TS93 U2/TS93 1-5/TS93 1-6 surface mounted, self-closing type swinging door closer. These devices may be used together to form a mechanically actuated coordinated pair of door closer.

These devices are to be installed on pairs of swing doors which are designed to be normally closed.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed for use with swinging type fire doors as closer.

Rev. 02-08-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager